

Certificate of Compliance

This certificate is issued for the following:

Steel Pipe Fittings for Automatic Fire Sprinkler Systems

Model	Product Type	End Connection	Sizes, NPS	Rated Working Pressure	
				psi	kPa
Schedule 40	ASTM A53	Welded	4, 5, 6, 8	300	2065
		Threaded			
		Rolled Groove			
		Cut Groove			

Prepared for:

Maruichi Leavitt Pipe & Tube LLC
1717 W. 115th Street, Chicago, IL 60643, United States


FM Approvals Class: 1630 (June 2021) – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: PR462175

Approval Granted: 25 April 2025

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.



David B. Fuller
VP, Manager – Fire Protection
FM Approvals
One Technology Way
Norwood, MA 02062

